



Long-Term Energy Optimization in Water Systems

Presented to: SWEEP 2018 Conference

Presented by: Hob Issa

Date: November 2018



Introduction to Lincus

The Water-Energy Nexus

Why this Segment is Important

Prioritizing Water Segment Opportunities

Hurdles and Strategies

Prioritizing Water Segment Opportunities

Case Studies




Introduction



Established in 2003


Offices:

- Tempe, AZ (HQ)
- Monrovia, CA
- San Diego, CA
- Emeryville, CA
- Chicago, IL



Why is this Segment Important?





Energy Consumption in the USA

- EPA estimates 3-4% of national electricity consumption.
- Largest consumer of energy in municipalities, ~30-40% of total energy consumed.

Annual USA Energy Savings for this Segment

- 12.9 Billion kWh
- \$1.224 Billion
- Assuming conservative energy savings of 10%

Lincus' WISE™

- Program Focuses on all electric consumption of this segment.
- Water-Energy Nexus
- GHG Reduction

Hurdles

- Lack of understanding by Customers of Utilityqualified measures
- Lack of staffing for project management by Customers
- Onerous procurement process
- Limited funding for the projects
- How to navigate Utility's incentive and rebate process for projects
- How to implement projects to sustain savings in the long-run



Strategies

End-to-End Customer Engagement

- Comparative Energy Analyses and Energy Engineering
- Objective Third-Party Technical Review
- Project Management
- Project energy-efficiency Scope-of-Work and Specifications
- Simplified Procurement
- Financing
- Ongoing Energy Management Tools



Example of IOU Process





Customer elects to participate in WISE Program Agreement



Perform Benchmarking Benchmarking Report



Energy assessment performed PFS & Customer Agreement & **OBF** Application



Application(s) submitted & IOU performs Pre-Inspection, Project Application Review, and Credit Check (OBF)



Project approved



RFP is developed which requires vendors to provide carrying cost for project until step 10 is reached



If applicable, OBF application is resubmitted based on final Contractor project cost.



Installation Commencement



Install Project **Installation Report**



IOU performs Post-Inspection and reviews Installation Report



Customer receives incentive and OBF (if applicable) check from IOU

Prioritizing Water Segment Opportunities



DG

- Solar photovoltaics
- In-conduit hydro
- CHP, fuel cells
- Small wind

ntegrated Water and Energy Management

- SCADA upgrades
- Load-shifting
- Demand response

Water Conservation

- Agricultural end-use water conservation programs
 - Residential and commercial conservation

Energy Efficiency – Hydraulic Modelling

- Leak detection and repair
- Pressure optimization
- Distribution optimization

Energy Efficiency – System Optimization


- Pump sequencing
- VFDs and controls
- Process optimization

Energy Efficiency – Component Optimization

- Pump efficiency improvement
- Valve replacements
- Blower efficiency improvement



Life Cycle Cost of a Pump




Why Pumps?

Recommended Pump Overall Plant Efficiency (OPE)

Motor HP	Low %	Fair %	Good %	Excellent				
				Well Pump	Booster	Submersible		
3 - 5	≤ 41.9	42.0 - 49.9	50.0 - 54.9	≥ 55.0	≥ 55.0	≥ 52.0		
7.5 - 10	≤ 44.9	45.0 - 52.9	53.0 - 57.9	≥ 58.0	≥ 60.0	≥ 55.0		
15 - 30	≤ 47.9	48.0 - 55.9	56.0 - 60.9	≥ 61.0	≥ 65.0	≥ 58.0		
40 - 60	≤ 52.9	53.0 - 59.9	60.0 - 64.9	≥ 65.0	≥ 70.0	≥ 62.0		
75 - up	≤ 55.9	56.0 - 62.9	63.0 - 68.9	≥ 69.0	≥ 72.0	≥ 66.0		


Why Pumps?

Baseline OPE % for Booster Pumps



6 out of 10 booster pumps need a pump retrofit

Baseline OPE % for Well Pumps



7 out of 10 well pumps need a pump retrofit

Pump Overhaul Measures




EE Measure	Typical OPE % Savings				
1. Pump Bowl Replacements	15% - 25%				
2. Impeller Replacements	5% - 15%				
3. Column Tube/Shaft Replacements	1% - 2%				
4. Others	System Specific				

Additional Measures include:

- Right Sizing Pumps
- Pump schedule changes (EE/DR)
- Matching system conditions with the design conditions
- Variable Speed Drives and High Efficiency motors

Improving OPE in Well Pumps





Number of Pumps with this Measure

(Pumps can have more than one measure installed)

^{*}Measure not incented by program



Water District Facts

- Service Territory: 47 square miles delivering ~18 billion gallons of water per year
- System: 13 distribution zones, 28 groundwater wells, 22 booster stations, 3 water treatment plants, and 34 reservoirs with 90 MG capacity
 - Well pumps are used to fill reservoirs for blending
 - Booster pumps distribute source water to the distribution zone through reservoir level onoff controls


Annual Electric Bill

~\$3.7 million w/ highest use in summer months



Benchmarking Analysis

- According to the California Energy Commission (CEC):
 - Water distribution consumes 700-1200 kWh/MG pumped
 - Groundwater sources consume anywhere from 700 kWh/MG to 1,800 kWh/MG pumped
- District's pumps consume an average of 1,403 kWh/MG based on the pump test data provided for review.





Executive Summary: Phase 1

	Energy Savings		Annual Utility	Measure Cost	Total	Net Measure	Simple	Savings: % of
Energy Efficiency Measure (EEM)	kW	kWh	Savings		Incentive	Cost	Payback	Total
EEM 1: Pump Efficiency Improvement	119.4	1,253,698	\$161,651	\$735,000	\$118,202	\$616,797	3.8	4%
EEM 2: Optimize Well Pump Sequencing	0	462,177	\$59,593	\$196,781	\$36,974	\$159,807	2.7	2%
EEM 3: Optimize Zone & Pump Sequencing	3.3	526,441	\$74,583	\$306,500	\$42,612	\$263,888	3.5	2%
EEM 4: Optimize Booster Pump Sequencing	85.02	527,149	\$74,683	\$479,353	\$54,926	\$424,427	5.7	2%
Totals	207.72	2,769,465	\$370,510	\$1,717,634	\$252,714	\$1,464,919	4.0	10%



EEM #1: District Wide Pump Overhauls: 4% in Energy Savings

- Overhauled 10 booster pumps (50-300hp)
- Overhauled 4 well pumps (100-500hp)
 - Existing overall plant efficiencies 57.9-66.9%
 - Proposed overall plant efficiencies 68-72%

EEM #2: Well Pump Sequencing: 2% in Energy Savings

- The energy intensity of pumps varies throughout the district's system
- The district installed kW meters and using existing flow meters to sequence 24 well pumps filling common reservoirs
- Pumps with lower energy intensity (kWh/AF or kWh/MG) were prioritized in meeting the system demands

Case Study: Zone Optimization & Sequencing



EEM #3: Zone Optimization & Sequencing: 2% in Energy Savings

- Eliminated requirement of 3A boosters to provide the additional head to maintain pressure in the subzone
- Boosters in Stations 3 & 3A with lower energy intensity are prioritized


EEM #4: Zone Optimization & Sequencing: 2% in Energy Savings

- The district installed kW meters
- Using existing flow meters we sequenced 47 booster pumps filling common reservoirs and supplying similar zones
- Pumps with lower energy intensity were prioritized in meeting the system demands

Calibrated Hydraulic Modeling



- Hydraulic Modeling allows for energy simulation of a water distribution system
- Can result in up to a 50% reduction in energy use
- Optimizes pressure in the system leading to lesser leaks
- Provides much-needed redundancy in the system by taking one pump out of operation



WISE™ Customers





































PADREDAM

NCWD











LIVERMORE





















































































What questions may we answer for you?



Contacts

Name: Hob Issa Title: Vice President Phone #: 949-244-6528

Email: hissa@lincus.com

Name: Cody Coeckelenbergh

Title: Director

Phone #: 626-241-2856 Email: CodyC@lincus.com



Thank You.

